

IEC 61850 Certificate Level A¹

Page 1/2

lecued to:

Schweitzer Engineering Laboratories, Inc. 2350 NE Hopkins Court Pullman, WA 99163-5603 USA

No. 74102139-MOC/INC 14-0133

For the server product: SEL-651R Recloser Control Version R404

Issued by:



The server product has not shown to be non-conforming to:

IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Device Test Procedures version 2.3 with TPCL² version 1.7, the product's protocol, model and technical issue implementation conformance statements: "IEC 61850 PICS SEL-651R, Protocol Implementation Conformance Statement, version 20131211", "IEC 61850 MICS SEL-651R, Protocol Implementation Conformance Statement, version 20131211" and "IEC61850 TICS SEL-651R, TISSUES Implementation Conformance Statement, version 20131211" and the extra information for testing: "IEC 61850 PIXIT SEL-651R, Protocol Implementation eXtra Information for Testing (PIXIT), version 20131211".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (16/24)

2 Data Sets (3/6)

5 Unbuffered Reporting (14/19)

6 Buffered Reporting (17/21)

9a GOOSE Publish (8/13)

9b GOOSE Subscribe (11/11)

12a Direct Control (7/12)

2c Enhanced Direct Control (7/13)

12d Enhanced SBO Control (12/19)

13 Time Synchronization (4/5)

14 File Transfer (4/7)

This certificate includes a summary of the test results as carried out at KEMA in Arnhem with UniCA 61850 Client simulator 4.27.04 with test suite 3.27.00 and UniCA 61850 Analyzer 5.27.04. This document has been issued for information purposes only, and the original paper copy of the KEMA report No. 74102139-MOC/INC 14-0132 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KEMA by SEL. The manufacturer's production process has not been assessed. This attestation does not imply that KEMA has approved any product other than the specimen tested.

Arnhem, December 22, 2013

M. Adriaensen

Director Intelligent Networks & Communication

R. Schimmel

Certification Manager

¹ Level A - Independent test lab with certified ISO 9001 Quality System

² TPCL - Test procedures change list

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA attestation is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.3 with TPCL version 1.7

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5	Srv8, SrvN1f
	Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	
2: Data Sets	Dset1, Dset10a, DsetN1ae	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10, Rp12	Rp5, Rp8, Rp9
	RpN1, RpN2, RpN3, RpN4	
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12, Br14	Br5, Br10, Br11
	BrN1, BrN2, BrN3, BrN4, BrN5	
9a: GOOSE Publish	Gop2, Gop3, Gop4, Gop7, Gop9, Gop10a	Gop1, Gop10b
9b: GOOSE Subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	Gos1b, Gos4
12a: Direct Control	CtiN3, CtiN8	Ctl2, CtlN10, CtlN11, DOns3
	DOns1	
12c: Enhanced Direct Control	CtiN3, CtiN8	Ctl2, CtlN10, CtlN11
	DOes2, DOes5	
12d: Enhanced SBO Control	Ctl3, CtlN1, CtlN2, CtlN3, CtlN4, CtlN9	Ctl2, CtlN10, CtlN11
	SBOes1, SBOes2, SBOes3	
13: Time Sync	Tm1, Tm2, TmN1	TmN2
14: File Transfer	Ft1, Ft2ab, Ft4, FtN1ab	