



**CONTROLLER OSCILLATORY AND FAST TRANSIENT SWC TEST REPORT**

<b>Client:</b>	Schweitzer Engineering Laboratories Inc., 2440 NE Hopkins Court, Pullman, WA, 99163 USA		
<b>Test Date:</b>	October 15 <sup>th</sup> , 2015	<b>Project:</b>	PL-27147
<b>Nameplate Data:</b>			
<b>Recloser Controller:</b>			
Manufacturer:	Schweitzer Engineering Laboratories, Inc.		
Model:	SEL-651RA		
Part No:	0651RA01XGAXAA1A111XBXXX		
Serial No.:	1152650818		
<b>Three-phase Recloser:</b>			
Manufacturer:	G & W Electric Company		
Type:	Viper-S		
Impulse level (BIL):	150 kV <sub>peak</sub>		
Rated voltage:	38 kV <sub>rms</sub>		
Rated current:	800 A <sub>rms</sub> continuous		
Serial No.:	2015-0821-0002		
<b>Test Standard:</b>	IEEE C37.60-2012, Clause 6.111.2: "Oscillatory and fast transients surge tests"		
<b>Test Witness:</b>	Mark Feltis – Schweitzer Engineering Laboratories Inc.,		
<b>Atmospheric Conditions:</b>			
Temperature	22.5 °C		
Relative humidity	57.7 %		
Barometric pressure	753.5 mmHg		
<b>Test Voltage:</b>	Oscillatory - 2.5 kV <sub>peak</sub> , Fast Transient – 4 kV <sub>peak</sub>		
<b>Test Procedure:</b>	The testing was in accordance with IEEE C37.90.1-2012. Test surges were applied to the control cable in common and transverse mode using an external coupling/decoupling network in accordance with Table 3 and 4 of IEEE C37.90.1. Signal and data circuits were tested using a capacitive clamp. The AC power supply was tested while connected to 120 Volts, 60 Hz supply for all tests.		
<b>Test Results:</b>	The controller and recloser operated normally following the Oscillatory and Fast Transient Tests performed in accordance with the test procedures as per the above document. The controller complied with requirements of "IEEE C37.60-2012, Clause 6.111.2".		
<b>Remarks:</b>	Viper-S voltage sensor board was modified prior to equipment successfully passing the test.		

Tested by:

  
\_\_\_\_\_  
Hamish Miller, EIT.  
Test Engineer, High Voltage Laboratory

Reviewed by:

  
\_\_\_\_\_  
Alex Babakov, P. Eng.  
Test Engineer, High Voltage Laboratory

Nov. 17, 2015

*This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.*

**Fast Transient Waveform Validity Tests**

(in accordance with IEEE Std C37.90.1-2012, Clause B.2)

Performed before the Fast Transient Test

1. Measuring system feed through test

Generator Output voltage   4   kV

Feed through voltage   2.1   V (pass if  $\leq 1\%$ )

2. Open circuit voltage waveform test

Recorded waveforms – Figures 1 and 2.

3. Test Generator performance verification

Test duration   60.0   s ( $\geq 60$  s)

Burst period   293.6   ms (240 to 360 ms)

Burst duration   14.9   ms (12 to 18 ms)

Repetition rate   2.5   kHz (2 to 3 kHz)

Impulse duration   62   ns (35 to 65 ns to 50% value)

Rise time   5.6   ns (3.5 to 6.5 ns – 10% to 90%)

Peak voltage level (no load)   4.20   kV (3.6 to 4.4 kV when set to 4 kV)

Output impedance   40.6    $\Omega$  (40 to 60  $\Omega$ )

4. Test Pass   X   Test Fail           




Figure 1




Figure 2

*This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.*

**Fast Transient Waveform Validity Tests**

(in accordance with IEEE Std C37.90.1-2012, Clause B.2)

Performed after the Fast Transient Test

1. Measuring system feed through test

Generator Output voltage   4   kV

Feed through voltage   11.6   V (pass if  $\leq 1\%$ )

2. Open circuit voltage waveform test

Recorded waveforms – Figures 1 and 2.

3. Test Generator performance verification

Test duration   60.0   s ( $\geq 60$  s)

Burst period   282.2   ms (240 to 360 ms)

Burst duration   14.8   ms (12 to 18 ms)

Repetition rate   2.6   kHz (2 to 3 kHz)

Impulse duration   35.3   ns (35 to 65 ns to 50% value)

Rise time   5.4   ns (3.5 to 6.5 ns – 10% to 90%)

Peak voltage level (no load)   4.18   kV (3.6 to 4.4 kV when set to 4 kV)

Output impedance   49.5    $\Omega$  (40 to 60  $\Omega$ )

4. Test Pass   X   Test Fail           




Figure 1




Figure 2

*This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.*

### Oscillatory Waveform Validity Tests

(in accordance with IEEE Std C37.90.1-2012, Clause B.2)

Performed before the Oscillatory SWC Test

1. Measuring system feed through test

Generator Output voltage 2.5 kV

Feed through voltage 9.4 V (pass ≤ 1%)

2. Open circuit voltage waveform test

Recorded waveforms – Figures 1 and 2.

3. Test Generator performance verification

Test duration 2.1 s (2 to 2.2 s)

Repetition rate 8 bursts per period (6-10 bursts per 16.7 ms)

Oscillation frequency 0.91 MHz (0.9 to 1.1 MHz)

Waveform envelope decay 5.1 μs (4 to 6 μs to 50%)

Rise time of the first peak 80 ns (60 to 90 ns – 10% to 90%)

Peak voltage level (no load) 2.25 kV (2.25 to 2.5 kV when set to 2.5 kV)

Output impedance 184 Ω (160 to 240 Ω)

4. Test Pass X Test Fail \_\_\_\_\_




Figure 1




Figure 2

*This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.*

**Oscillatory Waveform Validity Tests**

(in accordance with IEEE Std C37.90.1-2012, Clause B.2)

Performed after the Oscillatory SWC Test

1. Measuring system feed through test

Generator Output voltage 2.5 kV

Feed through voltage 14.7 V (pass ≤ 1%)

2. Open circuit voltage waveform test

Recorded waveforms – Figures 1 and 2.

3. Test Generator performance verification

Test duration 2.1 s (2 to 2.2 s)

Repetition rate 9 bursts per period (6-10 bursts per 16.7 ms)

Oscillation frequency 0.90 MHz (0.9 to 1.1 MHz)

Waveform envelope decay 5.8 μs (4 to 6 μs to 50%)

Rise time of the first peak 90 ns (60 to 90 ns – 10% to 90%)

Peak voltage level (no load) 2.41 kV (2.25 to 2.5 kV when set to 2.5 kV)

Output impedance 161 Ω (160 to 240 Ω)

4. Test Pass X Test Fail \_\_\_\_\_




Figure 1





Figure 2

*This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.*

**RECLOSER-CONTROLLER SIMULATED SURGE ARRESTER OPERATION TEST REPORT**

<b>Client:</b>	Schweitzer Engineering Laboratories Inc., 2440 NE Hopkins Court, Pullman, WA, 99163 USA	
<b>Test Date:</b>	October 15 <sup>th</sup> & 16 <sup>th</sup> , 2015	<b>Project:</b> PL-27147
<b>Nameplate Data:</b>		
<b>Recloser Controller:</b>		
Manufacturer:	Schweitzer Engineering Laboratories, Inc.	
Model:	SEL-651RA	
Part No:	0651RA01XGAXAA1A111XBXXX	
Serial No.:	1152650818	
<b>Three-phase Recloser:</b>		
Manufacturer:	G & W Electric Company	
Type:	Viper-S	
Impulse level (BIL):	150 kV <sub>peak</sub>	
Rated voltage:	38 kV <sub>rms</sub>	
Rated current:	800 A <sub>rms</sub> continuous	
Serial No.:	2015-0821-0002	
<b>Test Standard:</b>	IEEE Std C37.60-2012, Clause 6.111.3: "Simulated Surge Arrester Operation Test"	
<b>Test Witness:</b>	Mark Feltis – Schweitzer Engineering Laboratories Inc.,	
<b>Atmospheric Conditions:</b>	October 15 <sup>th</sup> , 2015	October 16 <sup>th</sup> , 2015
Temperature	22.5 °C	19.5 °C
Relative humidity	57.7 %	45.3 %
Barometric pressure	753.5 mmHg	750.0 mmHg
<b>Nominal Test Voltage and Current:</b>	120 kV <sub>peak</sub> (150 kV <sub>peak</sub> * 0.8), 6.0 kA <sub>peak</sub>	
<b>Test Configurations Tested</b> (in accordance with the above standard):		
1 – 15 surges of positive polarity and 15 surges of negative polarity were applied to the source bushing with the recloser open. 2 – 15 surges of positive polarity and 15 surges of negative polarity were applied to the source bushing with the recloser closed. 3 – 15 surges of positive polarity and 15 surges of negative polarity were applied to the load bushing with the recloser closed. 4 - 15 surges of positive polarity and 15 surges of negative polarity were applied to a properly rated transformer with the recloser open. 5 - 15 surges of positive polarity and 15 surges of negative polarity were applied to a properly rated transformer with the recloser closed.		
<b>Test Results:</b>	The controller and recloser complied with the requirements of IEEE Std C37.60-2012, Clause 6.111.3, Configurations 1 -5.	
<b>Remarks:</b>	Viper-S voltage sensor board was modified prior to equipment successfully passing the test.	

Tested by:



Hamish Miller, EIT.  
 Test Engineer, High Voltage Laboratory

Reviewed by:



Alex Babakov, P. Eng.  
 Test Engineer, High Voltage Laboratory

*This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.*