

CONTROLLER OSCILLATORY AND FAST TRANSIENT SWC TEST REPORT

Client:	Schweitzer Engineering Laboratories Inc., 2440 NE Hopkins Court, Pullman, WA, 99163 USA	
Test Date:	October 9 th , 2015	Project: PL-27147
Nameplate Data:		
Recloser Controller:		
Manufacturer:	Schweitzer Engineering Laboratories, Inc.	
Model:	SEL-651RA	
Part No:	0651RA01XFAXAA1A111XCXXX	
Serial No.:	1152590494	
Three-phase Recloser:		
Manufacturer:	Eaton	
Type:	Kyle Nova15	
Impulse level (BIL):	110 kV _{peak}	
Rated voltage:	15.5 kV _{rms}	
Rated current:	630 A _{rms} continuous	
Serial No.:	CP571 404340-SH	
Test Standard:	IEEE C37.60-2012, Clause 6.111.2: "Oscillatory and fast transients surge tests"	
Test Witness:	Mark Feltis – Schweitzer Engineering Laboratories Inc.,	
Atmospheric Conditions:	Temperature	22.1 °C
	Relative humidity	55.6 %
	Barometric pressure	748.0 mmHg
Test Voltage:	Oscillatory - 2.5 kV _{peak} , Fast Transient – 4 kV _{peak}	
Test Procedure:	The testing was in accordance with IEEE C37.90.1-2012. Test surges were applied to the control cable in common and transverse mode using an external coupling/decoupling network in accordance with Table 3 and 4 of IEEE C37.90.1. Signal and data circuits were tested using a capacitive clamp. The AC power supply was tested while connected to 120 Volts, 60 Hz supply for all tests.	
Test Results:	The controller and recloser operated normally following the Oscillatory and Fast Transient Tests performed in accordance with the test procedures as per the above document. The controller complied with requirements of "IEEE C37.60-2012, Clause 6.111.2".	
Remarks:	None	

Tested by:



Hamish Miller, EIT.
 Test Engineer, High Voltage Laboratory

Reviewed by:



Alex Babakov, P. Eng.
 Test Engineer, High Voltage Laboratory

This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.

Fast Transient Waveform Validity Tests

(in accordance with IEEE Std C37.90.1-2012, Clause B.2)

Performed before the Fast Transient Test

1. Measuring system feed through test

Generator Output voltage 4 kV

Feed through voltage 2.1 V (pass if $\leq 1\%$)

2. Open circuit voltage waveform test

Recorded waveforms – Figures 1 and 2.

3. Test Generator performance verification

Test duration 60.0 s (≥ 60 s)

Burst period 293.6 ms (240 to 360 ms)

Burst duration 14.9 ms (12 to 18 ms)

Repetition rate 2.5 kHz (2 to 3 kHz)

Impulse duration 62 ns (35 to 65 ns to 50% value)

Rise time 5.6 ns (3.5 to 6.5 ns – 10% to 90%)

Peak voltage level (no load) 4.20 kV (3.6 to 4.4 kV when set to 4 kV)

Output impedance 40.6 Ω (40 to 60 Ω)

4. Test Pass X Test Fail




Figure 1




Figure 2

This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.

Fast Transient Waveform Validity Tests

(in accordance with IEEE Std C37.90.1-2012, Clause B.2)

Performed after the Fast Transient Test

1. Measuring system feed through test

Generator Output voltage 4 kV

Feed through voltage 11.6 V (pass if $\leq 1\%$)

2. Open circuit voltage waveform test

Recorded waveforms – Figures 1 and 2.

3. Test Generator performance verification

Test duration 60.0 s (≥ 60 s)

Burst period 282.2 ms (240 to 360 ms)

Burst duration 14.8 ms (12 to 18 ms)

Repetition rate 2.6 kHz (2 to 3 kHz)

Impulse duration 35.3 ns (35 to 65 ns to 50% value)

Rise time 5.4 ns (3.5 to 6.5 ns – 10% to 90%)

Peak voltage level (no load) 4.18 kV (3.6 to 4.4 kV when set to 4 kV)

Output impedance 49.5 Ω (40 to 60 Ω)

4. Test Pass X Test Fail _____




Figure 1




Figure 2

This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.

Oscillatory Waveform Validity Tests

(in accordance with IEEE Std C37.90.1-2012, Clause B.2)

Performed before the Oscillatory SWC Test

1. Measuring system feed through test

Generator Output voltage 2.5 kV

Feed through voltage 9.4 V (pass ≤ 1%)

2. Open circuit voltage waveform test

Recorded waveforms – Figures 1 and 2.

3. Test Generator performance verification

Test duration 2.1 s (2 to 2.2 s)

Repetition rate 8 bursts per period (6-10 bursts per 16.7 ms)

Oscillation frequency 0.91 MHz (0.9 to 1.1 MHz)

Waveform envelope decay 5.1 μs (4 to 6 μs to 50%)

Rise time of the first peak 80 ns (60 to 90 ns – 10% to 90%)

Peak voltage level (no load) 2.25 kV (2.25 to 2.5 kV when set to 2.5 kV)

Output impedance 184 Ω (160 to 240 Ω)

4. Test Pass X Test Fail _____




Figure 1




Figure 2

This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.

Oscillatory Waveform Validity Tests

(in accordance with IEEE Std C37.90.1-2012, Clause B.2)

Performed after the Oscillatory SWC Test

1. Measuring system feed through test

Generator Output voltage 2.5 kV

Feed through voltage 14.7 V (pass ≤ 1%)

2. Open circuit voltage waveform test

Recorded waveforms – Figures 1 and 2.

3. Test Generator performance verification

Test duration 2.1 s (2 to 2.2 s)

Repetition rate 9 bursts per period (6-10 bursts per 16.7 ms)

Oscillation frequency 0.90 MHz (0.9 to 1.1 MHz)

Waveform envelope decay 5.8 μs (4 to 6 μs to 50%)

Rise time of the first peak 90 ns (60 to 90 ns – 10% to 90%)

Peak voltage level (no load) 2.41 kV (2.25 to 2.5 kV when set to 2.5 kV)

Output impedance 161 Ω (160 to 240 Ω)

4. Test Pass X Test Fail _____




Figure 1





Figure 2

This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.

RECLOSER-CONTROLLER SIMULATED SURGE ARRESTER OPERATION TEST REPORT

Client:	Schweitzer Engineering Laboratories Inc., 2440 NE Hopkins Court, Pullman, WA, 99163 USA	
Test Date:	October 9 th & 14 th , 2015	Project: PL-27147
Nameplate Data:		
Recloser Controller:		
Manufacturer:	Schweitzer Engineering Laboratories, Inc.	
Model:	SEL-651RA	
Part No:	0651RA01XDAXAA1A111XCXXX	
Serial No.:	1152590494	
Three-phase Recloser:		
Manufacturer:	Eaton	
Type:	Kyle Nova15	
Impulse level (BIL):	110 kV _{peak}	
Rated voltage:	15.5 kV _{rms}	
Rated current:	630 A _{rms} continuous	
Serial No.:	CP571 404340-SH	
Test Standard:	IEEE Std C37.60-2012, Clause 6.111.3: "Simulated Surge Arrester Operation Test"	
Test Witness:	Mark Feltis – Schweitzer Engineering Laboratories Inc.,	
Atmospheric Conditions:	October 9 th , 2015	October 14 th , 2015
Temperature	22.1 °C	18.8 °C
Relative humidity	55.6 %	50.8 %
Barometric pressure	748.0 mmHg	758.0 mmHg
Nominal Test Voltage and Current:	88 kV _{peak} (110 kV _{peak} * 0.8), 6.0 kA _{peak}	
Test Configurations Tested (in accordance with the above standard):		
<p>1 – 15 surges of positive polarity and 15 surges of negative polarity were applied to the source bushing with the recloser open.</p> <p>2 – 15 surges of positive polarity and 15 surges of negative polarity were applied to the source bushing with the recloser closed.</p> <p>3 – 15 surges of positive polarity and 15 surges of negative polarity were applied to the load bushing with the recloser closed.</p> <p>4 - 15 surges of positive polarity and 15 surges of negative polarity were applied to a properly rated transformer with the recloser open.</p> <p>5 - 15 surges of positive polarity and 15 surges of negative polarity were applied to a properly rated transformer with the recloser closed.</p>		
Test Results:	The controller and recloser complied with the requirements of IEEE Std C37.60-2012, Clause 6.111.3, Configurations 1-5.	
Remarks:	None	

Tested by:



Hamish Miller, EIT.
Test Engineer, High Voltage Laboratory

Reviewed by:



Alex Babakov, P. Eng.
Test Engineer, High Voltage Laboratory

This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.