

Powertech Labs Inc. 12388 - 88th Avenue Surrey, British Columbia Canada V3W 7R7

Tel: (604)590-7500 Fax: (604)590-5347 www.powertech.bc.ca

CONTROLLER OSCILLATORY AND FAST TRANSIENT SWC TEST REPORT

Client: Schweitzer Engineering Laboratories Inc., 2440 NE Hopkins Court, Pullman, WA, 99163 USA				
Test Date:	October 7 th ,2015	Project:	PL-27147	
Nameplate Data: <i>Recloser Controller:</i> Manufacturer: Model: Part No: Serial No.:	Schweitzer Engineering Laboratories, Inc. SEL-651R-2 0651R2A3XGA8AA1111XXXX 1152590493			
Three-phase Recloser: Manufacturer: Type: Impulse level (BIL): Rated voltage: Rated current: Serial No.:	Tavrida Electric, Inc. OSM25_AL_2(630_150_2) 150 kV _{peak} 27 kV _{rms} 630 A _{rms} continuous 163174			
Test Standard:	IEEE C37.60-2012, Clause 6.111.2: "Oscillatory and fast transients surge tests"			
Test Witness:	Adrian Genz – Tavrida Electric NA			
Atmospheric Condition	Relative humidity 57.8	1 °C 8 % 0 mmHg		
Test Voltage:	Oscillatory - 2.5 kV _{peak} , Fast Transient – 4 kV _{peak}			
Test Procedure:	The testing was in accordance with IEEE C37.90.1-2012. Test surges were applied to the control cable in common and transverse mode using an external coupling/decoupling network in accordance with Table 3 and 4 of IEEE C37.90.1. Signal and data circuits were tested using a capacitive clamp. The AC power supply was tested while connected to 120 Volts, 60 Hz supply for all tests.			
Test Results:	The controller and recloser operated normally following the Oscillatory and Fast Transient Tests performed in accordance with the test procedures as per the above document. The controller complied with requirements of "IEEE C37.60-2012, Clause 6.111.2".			
Remarks:	None			

Tested by:

An

Hamish Miller, EIT. Test Engineer, High Voltage Laboratory Reviewed by:

11.6,2015

Alex Babakov, P. Eng. Test Engineer, High Voltage Laboratory

This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.

Project No.: PL-27147



Powertech Labs Inc. 12388 - 88th Avenue Surrey, British Columbia Canada V3W 7R7

RECLOSER-CONTROLLER SIMULATED SURGE ARRESTER OPERATION TEST REPORT

Client: Sc	hweitzer Engineering Laborator	ies Inc., 2440	NE Hopkins Court, Pullman, WA, 99163 USA	
Test Date:	October 7 th & 8 th ,2015	Project:	PL-27147	
Nameplate Data: <i>Recloser Controller:</i> Manufacturer: Model: Part No: Serial No.:	Schweitzer Engineering Labo SEL-651R-2 0651R2A3XGA8AA1111XXX 1152590493		ی ۲	
Three-phase Recloser: Manufacturer: Type: Impulse level (BIL): Rated voltage: Rated current: Serial No.:	Tavrida Electric, Inc. OSM25_AL_2(630_150_2) 150 kV _{peak} 27 kV _{rms} 630 A _{rms} continuous 163174		ж 1	
Test Standard:	IEEE Std C37.60-2012, Clause 6.111.3: "Simulated Surge Arrester Operation Test"			
Test Witness:	Adrian Genz – Schweitzer Engineering Laboratories Inc.,			
Atmospheric Conditions:October 7 th , 2015October 8 th , 2015				
	Relative humidity 57	2.1 °C 7.8 % 54.0 mmHg	20.6 °C 62.4 % 754.0 mmHg	
Nominal Test Voltage and Current: 120 kV _{peak} (150 kV _{peak} * 0.8), 6.0 kA _{peak}				
 Test Configurations Tested (in accordance with the above standard): 1 - 15 surges of positive polarity and 15 surges of negative polarity were applied to the source bushing with the recloser open. 2 - 15 surges of positive polarity and 15 surges of negative polarity were applied to the source bushing with the recloser closed. 3 - 15 surges of positive polarity and 15 surges of negative polarity were applied to the load bushing with the recloser closed. 4 - 15 surges of positive polarity and 15 surges of negative polarity were applied to a properly rated transformer with the recloser open. 5 - 15 surges of positive polarity and 15 surges of negative polarity were applied to a properly rated transformer with the recloser closed. 				
Test Results:	The controller and recloser complied with the requirements of IEEE Std C37.60-2012, Clause 6.111.3, Configurations 1-5.			
Remarks:	None			

Tested by:

Hamish Miller, EIT. Test Engineer, High Voltage Laboratory Reviewed by:

DU.

Alex Babakov, P. Eng. Test Engineer, High Voltage Laboratory

This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.