

**ANNEX E**

**PIXIT template for Server**

Protocol Implementation eXtra Information for Testing (PIXIT)  
for the IEC 61850 Edition 2 server interface in SEL-751 and SEL-787L

Version 1  
January 23, 2024

Based Upon UCAlug Server PIXIT Template version 21

# PIXIT for Server

## Introduction

This document specifies the protocol implementation extra information for testing (PIXIT) of the IEC 61850 interface in  
 SEL-751 with firmware version R401,  
 SEL-787L with firmware version R401.  
 All variants have the same IEC 61850 library LIB61850ID=27A190B2 and use the same hardware

Together with the PICS and the MICS the PIXIT forms the basis for a conformance test according to IEC 61850-10. The PIXIT entries contain information, which is not available in the PICS, MICS, TICS documents or SCL file.

Each table specifies the PIXIT for applicable ACSI service model as structured in IEC 61850-10. The “Ed” column indicates if the entry is applicable for IEC 61850 Edition 1 and/or Edition 2. A hyphen (“-“) in the Ed column indicates the PIXIT entry is not applicable for any version.

## PIXIT for Documentation

ID	Ed	Description	Value / Clarification
Do1	2	How to expose required firmware versions	Perform the following to display firmware version from the front panel with LCD display: <ul style="list-style-type: none"> <li>• From the initial screen press ENTER.</li> <li>• Repeatedly press the down arrow button until <b>STATUS</b> is selected then press ENTER</li> <li>• Repeatedly press the down arrow button until <b>RELAY STATUS</b> is selected then press ENTER.</li> <li>• Repeatedly press the down arrow button until <b>FID</b> is displayed</li> </ul> From the front panel with touchscreen display: <ul style="list-style-type: none"> <li>• Press Home button if the touchscreen is Off</li> </ul>

ID	Ed	Description	Value / Clarification
			<ul style="list-style-type: none"> <li>Press <b>DEVICE INFO</b> and then press <b>STATUS</b></li> <li>FID is listed ON THE THIRD LINE</li> </ul> <p>From a terminal session, issue the ID command. FID is listed as the first entry in the response.</p> <p>From MMS. FID is store in LLN0.DC.NamPlt.swRev</p>

### PIXIT for Configuration

ID	Ed	Description	Value / Clarification
Cf1	2	Can IED tool export ICD file or IID file (SICS I12)	ICD: Y IID: Y

### PIXIT for Association model

ID	Ed	Description	Value / Clarification
As1	1	Maximum number of clients that can set-up an association simultaneously	7
As2	1,2	TCP_KEEPALIVE value. The recommended range is 1..20s	1-20 seconds  Note: This time is settable through the enabling ETCPKA and selecting the range in sec in KAIDLE in the SET P 1 settings.
As3	1,2	Lost connection detection time	1-20 seconds
As4	-	Authentication is not supported yet	

ID	Ed	Description	Value / Clarification
As5	1,2	<p>What association parameters are necessary for successful association: Called values:</p> <p>Calling values:</p>	<p>Transport selector Y Session selector Y Presentation selector Y AP Title N AE Qualifier N other</p> <p>Transport selector N Session selector N Presentation selector N AP Title N AE Qualifier N other</p>
As6	1,2	<p>If association parameters are necessary for association, describe the correct Called values: e.g.</p> <p>Calling parameters: e.g.</p>	<p>Transport selector NA Session selector NA Presentation selector NA AP Title NA AE Qualifier NA other</p> <p>Transport selector 0001 Session selector 0001 Presentation selector 00000001 AP Title NA AE Qualifier NA other</p>
As7	1,2	What is the maximum and minimum MMS PDU size	<p>Max MMS PDU size 12000 Min MMS PDU size 512</p>
As8	1,2	What is the maximum start up time after a power supply interrupt	~15 seconds
As9	1,2	<p>Does this device function only as test equipment? (test equipment need not have a non-volatile configuration; but it cannot be part of the substation automation system)</p>	N
As10	2	How does the server behave when the associate request fails	The server does not send the associate request.

## PIXIT for Server model

ID	Ed	Description	Value / Clarification
Sr1	1,2	Which analogue value (MX) quality bits are supported (can be set by server)	Validity: Y Good, Y Invalid, N Reserved, N Questionable Detail Quality N Overflow N OutofRange N BadReference N Oscillatory Y Failure N OldData N Inconsistent N Inaccurate Miscellaneous: Y Source Y Test N OperatorBlocked
Sr2	1,2	Which status value (ST) quality bits are supported (can be set by server)	Validity: Y Good, Y Invalid, N Reserved, N Questionable Detail Quality N BadReference N Oscillatory Y Failure N OldData N Inconsistent N Inaccurate Miscellaneous: Y Source Y Test N OperatorBlocked
Sr3	-	What is the maximum number of data object references in one GetDataValues request	Deprecated
Sr4	-	What is the maximum number of data object references in one SetDataValues request	Deprecated
Sr5	1	Which Mode values are supported <sup>1</sup>	On Y [On-]Blocked Y

<sup>1</sup> IEC 61850-6:2009 clause 9.5.6 states that if only a subrange of the enumeration value set is supported, this shall be indicated within an ICD file by an enumeration type, where the unsupported values are missing

ID	Ed	Description	Value / Clarification
			Test Y Test/Blocked Y Off Y

#### PIXIT for Data set model

ID	Ed	Description	Value / Clarification
Ds1	1	What is the maximum number of data elements in one data set (compare ICD setting)	Not Applicable
Ds2	1	How many persistent data sets can be created by one or more clients (this number includes predefined datasets)	Not Applicable
Ds3	1	How many non-persistent data sets can be created by one or more clients	Not Applicable

#### PIXIT for Substitution model

ID	Ed	Description	Value / Clarification
Sb1	1	Are substituted values stored in volatile memory	Not Applicable

#### PIXIT for Setting group control model

ID	Ed	Description	Value / Clarification
Sg1	1	What is the number of supported setting groups for each logical device	Not Applicable
Sg2	1,2	What is the effect of when and how the non-volatile storage is updated (compare IEC 61850-8-1 §16.2.4)	Not Applicable
Sg3	1	Can multiple clients edit the same setting group	Not Applicable
Sg4	1	What happens if the association is lost while editing a setting group	Not Applicable
Sg5	1	Is EditSG value 0 allowed	Not Applicable
Sg6	2	When ResvTms is not present how long is an edit setting group locked	Not Applicable
Sg7	2	Can the active setting group be changed locally?	Y Notes: Disable the priority by issuing the SET G SS1 0 command and saving the changes (Y), then issue GRO n command to

ID	Ed	Description	Value / Clarification
		Can a setting in the active setting group be changed locally	change the group, where n =1-4. Y

### PIXIT for Reporting model

ID	Ed	Description	Value / Clarification
Rp1	1	The supported trigger conditions are (compare PICS)	integrity Y data change Y quality change Y data update Y general interrogation Y
Rp2	1	The supported optional fields are	sequence-number Y report-time-stamp Y reason-for-inclusion Y data-set-name Y data-reference Y buffer-overflow Y entryID Y conf-rev Y segmentation Y
Rp3	1,2	Can the server send segmented reports (when not supported the device shall refuse an association request with a smaller than minimum PDU size)	Y
Rp4	1,2	Mechanism on second internal data change notification of the same analogue data value within buffer period (Compare IEC 61850-7-2 Ed2 §17.2.2.9)	Send report immediately
Rp5	1	Multi client URCB approach (compare IEC 61850-7-2:2003 §14.2.1)	Each URCB is visible to all clients.
Rp6	-	What is the format of EntryID	Deprecated
Rp7	1,2	What is the buffer size for each BRCB or how many reports can be buffered	120k bytes or 200 reports, whichever limit is reached first.
Rp8	-	Pre-configured RCB attributes that are dynamic, compare SCL report settings	Deprecated
Rp9	1	May the reported data set contain: - structured data objects - data attributes	Y Y
Rp10	1,2	What is the scan cycle for binary events Is this fixed, configurable	4 ms Fixed

ID	Ed	Description	Value / Clarification
Rp11	1	Does the device support to pre-assign a RCB to a specific client in the SCL	N
Rp12	2	After restart of the server is the value of ConfRev restored from the original configuration or retained prior to restart	Restored from original configuration
Rp13	1,2	Does the server accept any client to configure / enable an RCB with BRCB.ResvTms=-1 or URCB.Resv=T? What fields are used to do the identification?	Not Applicable
Rp14	1,2	When BRCB.ResvTms is exposed, what is the default value for BRCB.ResvTms if client does not write (must be > 0) or When BRCB.ResvTms is not exposed, what is the internal reservation time (must be >= 0) Note: for Amd1 the client shall always write ResvTms and ResvTms is mandatory	N/A  0 seconds
Rp15	2	Is data model db=0 supported	N

#### PIXIT for Logging model

ID	Ed	Description	Value / Clarification
Lg1	1,2	What is the default value of LogEna (Compare IEC 61850-8-1 §17.3.3.2.1, the default value should be FALSE)	Not Applicable
Lg2	-	What is the format of EntryID	Deprecated
Lg3	1,2	Are there multiple Log Control Blocks that specify the Journaling of the same MMS NamedVariable and TrgOps and the Event Condition (Compare IEC 61850-8-1 §17.3.3.3.2)	Not Applicable
Lg4	-	Pre-configured LCB attributes that cannot be changed online	Not Applicable
Lg5	1	Which TrgOps are supported for logging  (note Ed2 and up requires support for all TrgOps)	Not Applicable



## PIXIT for GOOSE publish model

ID	Ed	Description	Value / Clarification
Gp1	1,2	Can the test (Ed1) / simulation (Ed2) flag in the published GOOSE be set Note: simulation is intended for test equipment	Y  Notes: Go to CAL level. If the DUT ask for a password to enter in level CAL: ACC = OTTER 2AC = TAIL CAL = CLARKE  To enable the simulation bit in a GOOSE publication; from a terminal session, issue the PUB SIM GOO command. To disable the simulation bit, issue PUB SIM OFF command.
Gp2	1	What is the behaviour when the GOOSE publish configuration is incorrect	Not Applicable
Gp3	1,2	Published FCD supported common data classes are	ACD, ACT, BCR, BTS, CMV, CTS, DEL, DPC, DPL, ENS, ENC, INC, ING, INS, LPL, MV, ORG, SEQ, SPC, SPG, SPS, STS, TSG, UTS, VSG, VSS and WYE
Gp4	1,2	What is the maximum value of TAL (maxTime) Is it fixed or configurable	60000 ms Configured by SCL
Gp5	1,2	What is the fastest retransmission time	4 ms Configured by SCL
Gp6	-	Can the GOOSE publish be turned on / off by using SetGoCBValues(GoEna)	Deprecated See PICS – SetGoCBValues
Gp7	1,2	What is the initial GOOSE sqNum after restart	sqNum = 0
Gp8	1	May the GOOSE data set contain: - structured data objects (FCD) - timestamp data attributes	Y Y
Gp9	1,2	Does Server or ICT refuse GOOSE payload dataset length greater than SCSM supports?	Y

### PIXIT for GOOSE subscribe model

ID	Ed	Description	Value / Clarification
Gs1	1,2	<p>What elements of a subscribed GOOSE message are checked to decide the message is valid and the allData values are accepted? If yes, describe the conditions.</p> <p>Notes:</p> <ul style="list-style-type: none"> <li>the VLAN tag may be removed by an Ethernet switch and shall not be checked</li> <li>the simulation flag shall always be checked (Ed2)</li> <li>the ndsCom shall always be checked</li> </ul>	<p>Y destination MAC address</p> <p>Y APPID</p> <p>Y gocbRef</p> <p>N timeAllowedtoLive</p> <p>Y datSet</p> <p>Y gold</p> <p>N T</p> <p>N stNum</p> <p>N sqNum</p> <p>Y simulation / test</p> <p>Y confRev</p> <p>Y ndsCom</p> <p>Y numDatSetEntries</p> <p>Y out-of-order dataset members</p>
Gs2	1,2	<p>When is a subscribed GOOSE marked as lost</p> <p>(TAL = time allowed to live value from the last received GOOSE message)</p>	<p>d) other (describe)</p> <p>GOOSE messages are not accepted or rejected based on TAL from the last received GOOSE message. The device sets an error status for the subscription if a GOOSE message is not received within the TAL interval. The device can be configured to transmit the error status in a GOOSE publication.</p>
Gs3	1,2	<p>What is the behaviour when one or more subscribed GOOSE messages is not received or syntactically incorrect (missing GOOSE)</p>	<p>If GOOSE messages are skipped, the GOOSE subscriber will issue an out-of-sequence error and wait for the next message to update the status. For syntax errors, the GOOSE subscriber will issue message-corrupted error and wait for the next message to update the status.</p>
Gs4	1,2	<p>What is the behaviour when a subscribed GOOSE message is out-of-order</p>	<p>The GOOSE subscriber will issue an out-of-sequence error and process the received GOOSE message.</p>
Gs5	1,2	<p>What is the behaviour when a subscribed GOOSE message is duplicated</p>	<p>The GOOSE subscriber will issue an out-of-sequence error.</p>

ID	Ed	Description	Value / Clarification
Gs6	1	Does the device subscribe to GOOSE messages with/without the VLAN tag	Y, with the VLAN tag Y, without the VLAN tag
Gs7	1	May the GOOSE data set contain: - structured data objects (FCD) - timestamp data attributes	Y Y
Gs8	1,2	Subscribed FCD supported common data classes are	All CDCs except these: H MV, H WYE, H DEL, and CSD  <b>Notes:</b> Integer values are not supported, only support mapping Boolean and Analog.
Gs9	1	Are subscribed GOOSE with test=T (Ed1) / simulation=T (Ed2) accepted in test/simulation mode	Y
Gs10	1,2	Max number of dataset members	Count = 200
Gs11	1	Is Fixed-length encoded GOOSE supported	Y
Gs12	Amd1	Is IEC 62351-6 security supported	N
Gs13	Amd1	How does the subscriber handle incoming data flagged as test when the destination LN.Beh is On or Blocked?  Is this behavior:	Processed as Invalid  fixed

#### PIXIT for GOOSE performance

ID	Ed	Description	Value / Clarification
Gf1	1,2	Performance class	P1 = 3 ms
Gf2	1,2	GOOSE ping-pong processing method	Scan cycle based
Gf3	1,2	Application logic scan cycle (ms)	Max.      4 ms at 60 Hz 5 ms at 50 Hz
			Min.      2 ms at 60 Hz 5 ms at 50 Hz
Gf4	1	Maximum number of data attributes in GOOSE dataset (value and quality has to be counted as separate attributes)	Count =200

## PIXIT for Control model

ID	Ed	Description	Value / Clarification
Ct1	1	What control models are supported (compare ICD file for Ed2)	DOns: Y SBOns: N DOes: Y SBOes: Y
Ct2	1,2	Is the control model fixed, configurable and/or dynamic	Configurable
Ct3	-	Is TimeActivatedOperate supported (compare PICS or SCL)	Deprecated
Ct4	-	Is “operate-many” supported (compare sboClass)	Deprecated, see sboClass in datamodel (ICD)
Ct5	1	Will the DUT activate the control output when the test attribute is set in the SelectWithValue and/or Operate request (when N test procedure Ct12 is applicable)	Not Applicable
Ct6	-	What are the conditions for the time (T) attribute in the SelectWithValue and/or Operate request	Deprecated
Ct7	-	Is pulse configuration supported (compare pulseConfig)	Deprecated
Ct8	1,2	What is the behaviour of the DUT when the <a href="#">check conditions are not set</a>  This behaviour is:	Not Applicable

ID	Ed	Description	Value / Clarification
Ct9	1,2	Which additional cause diagnosis are supported	N Unknown Y Not-supported Y Blocked-by-switching-hierarchy Y Select-failed Y Invalid-position Y Position-reached N Step-limit Y Blocked-by-Mode N Blocked-by-process N Blocked-by-interlocking N Blocked-by-synchrocheck Y Command-already-in-execution N Blocked-by-health N 1-of-n-control N Abortion-by-cancel Y Time-limit-over N Abortion-by-trip Y Object-not-selected  <b>Edition 2 specific values:</b> Y Object-already-selected Y No-access-authority N Ended-with-overshoot N Abortion-due-to-deviation N Abortion-by-communication-loss N Blocked-by-command Y None Y Inconsistent-parameters Y Locked-by-other-client N PARAMETER-CHANGE-IN-EXECUTION (ED2 SEMANTICS)
Ct10	1,2	How to force a "test-not-ok" respond with SelectWithValue request	Send the SelectWithValue request with an orCat value greater than 8

ID	Ed	Description	Value / Clarification
Ct11	1,2	How to force a "test-not-ok" respond with Select request	The control service Select is not supported.
Ct12	1,2	How to force a "test-not-ok" respond with Operate request	DOns: SBOns: not supported DOes: SBOes: Send the Operate request with an orCat value greater than 8.
Ct13	1,2	Which origin categories are accepted in control direction	Y bay-control Y station-control Y remote-control Y automatic-bay Y automatic-station Y automatic-remote Y maintenance
Ct14	1,2	What happens if the orCat value is not supported or invalid	DOns: SBOns: Not Supported Does: SBOes: DUT issues "test-not-ok" response with AddCause value "Not-supported"
Ct15	1,2	Does the IED accept a SelectWithValue / Operate with the same control value as the current status value  Is this behaviour configurable	Dons: Y SBOns: NA Does: N SBOes: N Configurable N
Ct16	1	Does the IED accept a select/operate on the same control object from 2 different clients at the same time	DOns: N SBOns: NA DOes: N SBOes: N
Ct17	1	Does the IED accept a Select/SelectWithValue from the same client when the control object is already selected (Tissue #334)	SBOns: NA SBOes: N

ID	Ed	Description	Value / Clarification
Ct18	1	Deprecated	
Ct19	-	Can a control operation be blocked by Mod=Off or [On-]Blocked (Compare PIXIT-Sr5)	Deprecated
Ct20	1,2	Does the IED support local / remote operation	Y
Ct21	1,2	Does the IED send an InformationReport with LastApplError as part of the Operate response- for control with normal security	SBOs: NA Dons: Y
Ct22	2	How to force a "parameter-change-in-execution"	SBOs: Not Applicable SBOes: Not Applicable
Ct23	1,2	How many SBOs/SBOes control objects can be selected at the same time?	SBOs: N/A SBOes: multiple = 10
Ct24	1,2	Can a controllable object be forced to keep its old state e.g. Internal Controllable Objects may not be accessible to force this, whereas a switch like Circuit Breaker outside the DUT can?	Y
Ct25	1,2	When CDC=DPC is supported, is it possible to have DPC (Controllable Double Point) go to the intermediate state? (00)	Y
Ct26	1,2	Name an enhanced security control point (if any) with a finite operate timeout  Specify the operate timeout (in milliseconds)	SEL_7XX_1PRO/BKR1CSWI1,  DOes: Configurable in the CID file SBOes: Configurable in the CID file  Default: 10 seconds
Ct27	2	Does the IED support control objects with external signals?	Dons: Y SBOs: Not Applicable Does: Y SBOes: Y
Ct28		Deprecated, kept as placeholder	
Ct29	Amd1	Does the IED support XCBR/XSWI.Loc=False and LLN0/CSWI.Loc=True  When yes, does the IED accept the control when orCat=1 or 4 Local	DOs: N SBOs: N/A DOes: N SBOes: Y

ID	Ed	Description	Value / Clarification
Ct30	2	What is the Operate timeout?	operTimeout in data model

### PIXIT for Time synchronisation model

ID	Ed	Description	Value / Clarification
Tm1	1	What time quality bits are supported (may be set by the IED) Note: Ability to set ClockNotSynchronized and LeapSecondKnown is mandatory in Ed2	Y LeapSecondsKnown Y ClockFailure Y ClockNotSynchronized
Tm2	1,2	Describe the behaviour when all time server(s) cease to respond  What is the time server lost detection time	Assert ClockNotSynchronized after lost detection time 5-20 seconds depending on DUT settings. Default 5 seconds.
Tm3	1,2	How long does it take to take over the new time from time server	15-3600 seconds depending on DUT settings. Default is 60 seconds.
Tm4	1,2	When is the time quality bit "ClockFailure" set	Not Applicable
Tm5	1	When is the time quality bit "Clock not Synchronized" set	When connection to all time servers is lost (see PIXIT-Tm2)
Tm6	-	Is the timestamp of a binary event adjusted to the configured scan cycle	Deprecated
Tm7	1	Does the device support time zone and daylight saving	Not Applicable
Tm8	1,2	Which attributes of the SNTP response packet are validated	Y Leap indicator not equal to 3 Y Mode is equal to SERVER Y OriginateTimestamp is equal to value sent by the SNTP client as Transmit Timestamp N RX/TX timestamp fields are checked for reasonableness Y SNTP version 3 and/or 4 N other (describe)
Tm9	1,2	When COMTRADE files are supported do these have local time or UTC time and is this configurable	Local N Configurable



**PIXIT for File transfer model**

ID	Ed	Description	Value / Clarification
Ft1	1	What is the structure of files and directories  Where are the COMTRADE files stored  Are COMTRADE files zipped and what files are included in each zip file	File system with folders  /COMTRADE/  Not zipped
Ft2	1,2	Directory names are separated from the file name by	"/"
Ft3	1	The maximum file name size including path (recommended 64 chars)	255 chars
Ft4	1,2	Are directory/file name case sensitive	Not case sensitive
Ft5	1,2	Maximum file size for SetFile	Not limited. Depends on available memory.
Ft6	1	Is the requested file path included in the MMS fileDirectory respond file name	Y
Ft7	1	Is the wild card supported in the MMS fileDirectory request	Yes, wild card = *
Ft8	1,2	Is it allowed that 2 clients get a file at the same time	Y same file Y different files
Ft9	1,2	Which files can be deleted	Not Applicable

**PIXIT for Service tracking model**

ID	Ed	Description	Value / Clarification
Tr1	2	Which ACSI services are tracked by LTRK.GenTrk	SpcTrk DpcTrk EncTrk1 BrcbTrk UrcbTrk SgcbTrk