



IEC 61850 Conformance and Interoperability Certificate Statement

SEL-451-4 Bay Control, Automation, and Protection System

In accordance with the IEC 61850 Communications Standard, this product has been certified by an independent test authority via unit level and product family or product platform tests. The associated certificate, No. 30620245, provided by the accredited third party, KEMA, is attached. This product also passed unit level and product platform tests performed internally using the same test tool and processes as used by the independent test authority. Additionally, this product has been confirmed to be interoperable with many third-party vendor peer IEDs and client applications.

A conformance test is the type test for communication and the system-related functions of the incorporated IEDs. As a global communications standard, the IEC 61850 series includes standardized conformance tests to ensure that all suppliers comply with applicable requirements. These requirements include MMS, GOOSE, SCL, and Time Services. SEL performed internal product-level conformance testing on the SEL-451-4 with a "pass verdict" using the KEMA Test Suite and internal standardized tests. These tests include Time Synchronization and File Transfer.

Compatible global standards for time services and data access have also been tested for compliance and interoperability. GPS-based time synchronization provides microsecond accuracy. These have been demonstrated compatible with standard software available on virtually all laptops, workstations, and servers throughout industry and the world.

Additionally, this device implementation has been demonstrated interoperable with other IEC 61850 vendor devices and software applications. Although not part of the conformance testing, confirmation of interoperability with third-party products has been verified also. Third-party vendors that SEL has demonstrated client/server and publisher/subscriber interoperability with include:

SISCO GE Team Artech	ABB Omicron Toshiba	Areva RFL ZIV	Cybectec Siemens
----------------------------	---------------------------	---------------------	---------------------

Vice President, SEL Research and Development

November 21, 2006

Date

IEC 61850 Certificate Level A¹

No. 30620245-Consulting 2006-1129

Issued to:
Schweitzer Engineering Laboratories
2440 N.E. Hopkins CT
Pullman, WA 99163
USA

For the product:
SEL-421
High Speed Line Protection, Automation
and Control System
Firmware R112
Ethernet Interface R102

Issued by:



The product has not shown to be non-conforming to:

IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1 Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 with product's Protocol and Model Implementation Conformance Statements: "SEL-421 Relay - Protection and Automation System - Instruction Manual; 20060814" and Technical Issues Conformance Statement: "IEC 61850 Tissues conformance statement for the SEL-421; 101306" and extra information for testing: "Protocol implementation extra information for testing (PIXIT) of the IEC 61850 communication interface in the SEL-421; 11082006".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures v1.1):

1 Basic Exchange (16/23)	9ab Generic Object Oriented Substation Event (13/20)
2 Data Sets (2/5)	12a Direct Control (4/11)
5 Unbuffered Reporting (11/13)	13 Time Synchronization (4/4)


This Certificate includes a summary of the test results as carried out at AEP/Dolan laboratories in Columbus OH, U.S.A. with UniCasim 61850 version 2.14.02 test system running test suite "61850 Conformance Test v2.14.03" and UniCA 61850 analyzer version 4.14.01. The test is based on the UCA International Users Group Device Test Procedures version 1.1. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 30620245-Consulting 2006-1128 will prevail.

The test have been carried out on one single specimen of the products as referred above and submitted to KEMA by Schweitzer Engineering Laboratories. The manufacturer's production process has not been assessed. This Certificate does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, November 21, 2006



S.J.L.M. Janssen
Managing Director KEMA Consulting



S.J.T. Mulder
Test Engineer

1) Level A – Independent Test Lab with certified ISO 9000 or ISO 17025 Quality System

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail

KEMA Nederland B.V.

Utrechtseweg 310, 6812 AR Arnhem; P.O. Box 9035, 6800 ET Arnhem, The Netherlands.
Telephone + 31 26 356 6142, Telefax + 31 26 515 456, Email sales@kema.com

Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 1.1

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abd, SrvN4	Srv6, Srv8
2: Data Sets	Dset1, DsetN1a	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7 RpN1, RpN2, RpN3, RpN4	Rp5, RpN5
9a: GOOSE publish	Gop2, Gop4, Gop7	Gop1, GopN1
9b: GOOSE subscribe	Gos1, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5	
12a: Direct control	CltN3, CltN8, DOns1	Ctl2
13: Time sync	Tm1, Tm2, TmN1	TmN2

KEMA

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail

KEMA Nederland B.V.

Utrechtseweg 310, 6812 AR Arnhem; P.O. Box 9035, 6800 ET Arnhem, The Netherlands.
Telephone + 31 26 356 6142, Telefax + 31 26 515 456, Email sales@kema.com