

# **Modern Solutions for Protection, Control, and Monitoring of Electric Power Systems**

## **Contents**

### **Preface**

### **Acknowledgements**

#### **1. Looking to the future**

- 1.1. Introduction
- 1.2. Time-synchronized measurements
- 1.3. Distribution systems
- 1.4. Transmission systems
- 1.5. Transformers
- 1.6. Buses
- 1.7. Generators
- 1.8. Wide-area systems
- 1.9. Communications
- 1.10. Integrated systems
- 1.11. Cybersecurity
- 1.12. Reliability and testing
- 1.13. Providing complete solutions
- 1.14. Asset management
- 1.15. Call to action

#### **2. Principles of time-synchronized systems**

- 2.1. Introduction
- 2.2. Time-synchronized measurement applications
- 2.3. Time synchronization
- 2.4. Time-synchronized phasors
  - 2.4.1. Synchrophasor definition
  - 2.4.2. Phasor angle reference for power system networks
  - 2.4.3. Synchrophasors provide power system state information
  - 2.4.4. Phasor angle and frequency are indicators of power system dynamic performance
- 2.5. Combining time-synchronized measurements with protection, control, and monitoring
  - 2.5.1. Architecture and advantages
  - 2.5.2. Performance of synchrophasor measurements
- 2.6. Processing synchrophasor information
  - 2.6.1. Phasor data concentration
  - 2.6.2. Synchrophasor-based protection, control, and monitoring
- 2.7. Synchrophasor systems
  - 2.7.1. Time sources

- 2.7.2. Phasor measurement devices
  - 2.7.3. Synchrophasor processors
  - 2.7.4. Communications networks
  - 2.7.5. Application software
- 2.8. References

### **3. Distribution system protection, automation, and monitoring**

- 3.1. Introduction
- 3.2. Limitations of traditional overcurrent protection
- 3.3. Modern solutions for distribution system protection, automation, and monitoring
  - 3.3.1. New abilities
  - 3.3.2. More sensitive fault detection
  - 3.3.3. Faster fault clearing
  - 3.3.4. Faster service restoration
  - 3.3.5. Higher reliability and lower cost
- 3.4. Negative-sequence overcurrent protection
  - 3.4.1. Negative-sequence overcurrent elements
  - 3.4.2. Coordinating negative-sequence overcurrent elements with phase overcurrent elements
- 3.5. Directional overcurrent protection
  - 3.5.1. Directional elements for phase fault protection
  - 3.5.2. Directional elements for ground fault protection
- 3.6. Improving ground fault protection sensitivity
  - 3.6.1. Ungrounded systems
  - 3.6.2. Resonant-grounded systems
  - 3.6.3. High-resistance grounded systems
  - 3.6.4. Effectively and low-impedance grounded systems
- 3.7. Effect of load current
  - 3.7.1. Traditional backup sensitivity limitations
  - 3.7.2. Increasing sensitivity for three-phase faults
  - 3.7.3. Increasing sensitivity for phase-to-phase faults
  - 3.7.4. Solving cold-load restoration current problems
  - 3.7.5. Avoiding sympathetic tripping
- 3.8. Distributed generation considerations
  - 3.8.1. Interconnection protection
  - 3.8.2. Distributed generation impacts utility system protection
- 3.9. High-speed distribution system protection
- 3.10. Reducing arc-flash hazards
  - 3.10.1. Methods for reducing arc-flash hazards
  - 3.10.2. Arc-flash protection
- 3.11. Distribution automation
  - 3.11.1. Distribution automation objectives
  - 3.11.2. Automatic throw-over schemes
  - 3.11.3. Distribution network fast-restoration schemes
  - 3.11.4. Centralized distribution automation systems
  - 3.11.5. Examples of distribution protection and automation systems
- 3.12. Faulted circuit indicators
  - 3.12.1. Benefits of faulted circuit indicators
  - 3.12.2. Faulted circuit indicator applications

- 3.12.3. Combine faulted circuit indicators and relays for fast fault location
  - 3.12.4. Other application considerations
  - 3.12.5. Looking to the future
- 3.13. References

## **4. Transmission line protection**

- 4.1. Introduction
- 4.2. Transmission systems of today and tomorrow
- 4.3. Line protection principles
- 4.4. Directional overcurrent protection
- 4.5. Distance protection
  - 4.5.1. Basic principle
  - 4.5.2. Distance protection schemes
  - 4.5.3. Distance element input signals
  - 4.5.4. Mho distance elements
  - 4.5.5. Quadrilateral distance elements
  - 4.5.6. Adaptive polarization
  - 4.5.7. High-speed elements
- 4.6. Sources of distance element errors
  - 4.6.1. Infeed effect
  - 4.6.2. Fault resistance
  - 4.6.3. Mutual coupling
  - 4.6.4. Load encroachment
  - 4.6.5. Effect of unfaulted phases
  - 4.6.6. Coupling-capacitor voltage transformer transients
  - 4.6.7. Loss of potential
- 4.7. Directional comparison protection
  - 4.7.1. Basic schemes
  - 4.7.2. Communications channels
  - 4.7.3. Scheme comparison
  - 4.7.4. Hybrid directional comparison scheme
- 4.8. Differential protection
  - 4.8.1. Communications channels and data alignment
  - 4.8.2. Alpha-plane differential element
  - 4.8.3. Advanced differential protection for multiterminal lines
  - 4.8.4. Combining differential and directional comparison protection in one relay
- 4.9. Phase comparison protection
- 4.10. Line protection sensitivity
  - 4.10.1. System grounding
  - 4.10.2. Relay sensitivity
  - 4.10.3. Power system unbalances
  - 4.10.4. Instrument transformer accuracy
- 4.11. Series-compensated line protection
  - 4.11.1. Voltage inversion affects directional discrimination
  - 4.11.2. Current inversion affects directional and differential discrimination
  - 4.11.3. Series capacitors affect distance measurement
  - 4.11.4. Directional comparison scheme security
- 4.12. Single-pole tripping
  - 4.12.1. Faulted-phase identification

- 4.12.2. Single-pole open considerations
- 4.12.3. Simultaneous faults
- 4.13. Power swing blocking and out-of-step tripping
  - 4.13.1. Impedance-based power swing detection
  - 4.13.2. Swing-center-voltage method for power swing detection
- 4.14. Thermal protection
- 4.15. Fault locating
  - 4.15.1. Single-ended methods
  - 4.15.2. Multiended method
- 4.16. References

## **5. Transformer protection and monitoring**

- 5.1. Introduction
- 5.2. Innovations in transformer protection and monitoring
- 5.3. Transformer differential protection
  - 5.3.1. Operation principle
  - 5.3.2. Current magnitude and phase-shift compensation
  - 5.3.3. Compensation for zero-sequence sources
  - 5.3.4. Differential current caused by magnetizing inrush, overexcitation, and CT saturation
  - 5.3.5. Discriminating internal faults from inrush and overexcitation conditions
  - 5.3.6. Microprocessor-based transformer differential elements
- 5.4. Restricted earth fault protection
  - 5.4.1. Traditional restricted earth fault protection
  - 5.4.2. Microprocessor-based relays improve restricted earth fault protection
- 5.5. Transformer overexcitation protection
- 5.6. Transformer overcurrent protection
  - 5.6.1. Transformer through-fault capability curves
  - 5.6.2. Transformer overcurrent relay protection
- 5.7. Transformer sudden-pressure and gas-accumulation protection
  - 5.7.1. Sudden-pressure protection
  - 5.7.2. Gas-accumulation protection
- 5.8. Combined transformer and bus protection
- 5.9. Redundancy considerations for transformer protection
- 5.10. Transformer monitoring
  - 5.10.1. Microprocessor-based IEDs perform transformer monitoring functions
  - 5.10.2. Transformer thermal model
  - 5.10.3. Insulation aging
  - 5.10.4. Through-fault monitoring
  - 5.10.5. Effect of through faults in transformer loss-of-life
  - 5.10.6. Integration of nonelectrical monitoring devices
- 5.11. References

## **6. Bus and breaker-failure protection**

- 6.1. Introduction
- 6.2. Modern solutions for bus protection
- 6.3. Bus arrangements
- 6.4. Bus protection schemes

- 6.4.1. Differential overcurrent protection
- 6.4.2. High-impedance differential protection
- 6.4.3. Percentage differential protection
- 6.4.4. Partial differential protection
- 6.4.5. Zone-interlocked protection
- 6.5. Breaker-failure protection
  - 6.5.1. Impact of breaker-failure protection on power system stability
  - 6.5.2. General considerations
  - 6.5.3. Basic breaker-failure protection scheme
  - 6.5.4. Breaker-failure protection scheme with consistent delay
  - 6.5.5. Fast open-phase detectors
  - 6.5.6. Fast-reset breaker-failure protection scheme
  - 6.5.7. Breaker-failure scheme with alternate initiation logic
  - 6.5.8. Use different breaker-failure times for multiphase and single-phase-to-ground faults
  - 6.5.9. Breaker-failure application in multifunction relays
  - 6.5.10. Breaker-failure tripping
- 6.6. Integrated bus and breaker-failure protection
  - 6.6.1. Protection zone selection
  - 6.6.2. Bus differential and breaker-failure protection tripping
- 6.7. References

## **7. Generator protection and monitoring**

- 7.1. Introduction
- 7.2. Modern multifunction generator relays
- 7.3. Stator fault protection
  - 7.3.1. Phase fault protection
  - 7.3.2. Turn-to-turn fault protection
  - 7.3.3. Ground fault protection
- 7.4. Rotor fault protection
- 7.5. Abnormal operation protection
  - 7.5.1. Stator thermal protection
  - 7.5.2. Field thermal protection
  - 7.5.3. Current unbalance protection
  - 7.5.4. Loss-of-field protection
  - 7.5.5. Motoring protection
  - 7.5.6. Overexcitation protection
  - 7.5.7. Overvoltage and undervoltage protection
  - 7.5.8. Abnormal frequency protection
  - 7.5.9. Loss-of-synchronism protection
  - 7.5.10. Inadvertent energization protection
  - 7.5.11. Backup protection
- 7.6. Synchronism-checking and auto-synchronizing elements
- 7.7. P-Q plane based generator monitoring
- 7.8. SEL-300G relay application solutions
- 7.9. References

## **8. Wide-area protection, control, and monitoring**

- 8.1. Introduction
- 8.2. Assessing substation state and topology
  - 8.2.1. Topology processor
  - 8.2.2. Current processor
  - 8.2.3. Voltage processor
- 8.3. Determining power system state
  - 8.3.1. Traditional state estimation
  - 8.3.2. Synchrophasor-based state determination
  - 8.3.3. Remote measurement supervision
- 8.4. Detecting power system inter-area oscillations
  - 8.4.1. Signal modal representation
  - 8.4.2. Damping ratio
  - 8.4.3. Signal-to-noise ratio
  - 8.4.4. Identifying inter-area oscillation modes
  - 8.4.5. Modal-analysis-based system integrity protection system
- 8.5. Black-start validation and paralleling of islanded generators with a large system
- 8.6. Applying synchrophasors to predict voltage instability
- 8.7. Automatic generator shedding using synchrophasor angle measurements
- 8.8. Use synchrophasors for backup transmission line protection
  - 8.8.1. Faulted-phase identification
  - 8.8.2. Negative-sequence and zero-sequence current differential elements
  - 8.8.3. Protection element performance
- 8.9. Distributed bus differential protection
  - 8.9.1. Protection zone selection
  - 8.9.2. Current differential element
  - 8.9.3. Application example of bus differential protection
- 8.10. Power-swing and out-of-step detection using synchrophasors
  - 8.10.1. Power swing detection
  - 8.10.2. Out-of-step detection
  - 8.10.3. Predictive out-of-step tripping
  - 8.10.4. System integrity protection system for two-area power systems
- 8.11. Synchrophasor-based islanding detection
- 8.12. System integrity protection system using MIRRORED BITS communications
- 8.13. Load shedding to prevent voltage collapse
- 8.14. References

## **9. Power system communications**

- 9.1. Introduction
- 9.2. Communications system overview
  - 9.2.1. Pilot protection
  - 9.2.2. Substation and distribution automation
  - 9.2.3. Wide-area protection and control
  - 9.2.4. SCADA and EMS
  - 9.2.5. Security
  - 9.2.6. Engineering access and maintenance
  - 9.2.7. Example installation
- 9.3. Communications channels
  - 9.3.1. Channel capacity
  - 9.3.2. Channel reliability

- 9.3.3. Channel availability
- 9.3.4. Propagation delay
- 9.4. Fiber-optic-based communication
  - 9.4.1. Optical fiber types and characteristics
  - 9.4.2. Fiber-optic connectors and transceivers
  - 9.4.3. Dedicated fiber-optic channels
  - 9.4.4. Shared fiber-optic channels
- 9.5. Wireless systems
  - 9.5.1. Microwave
  - 9.5.2. Narrow-band VHF/UHF radio
  - 9.5.3. Spread-spectrum radio
- 9.6. Modern communication-based protection
  - 9.6.1. Communication-based protection schemes
  - 9.6.2. Improving the reliability of communication-based protection
  - 9.6.3. Communications standards
  - 9.6.4. Environmental and performance standards
- 9.7. MIRRORED BITS communications
  - 9.7.1. Description
  - 9.7.2. Security
  - 9.7.3. Dependability
  - 9.7.4. Channel performance monitoring
  - 9.7.5. Implementation example
  - 9.7.6. Logic processor
  - 9.7.7. MIRRORED BITS tester
- 9.8. Ethernet-based communication
  - 9.8.1. Ethernet port speed and fiber-optic interface
  - 9.8.2. Full-duplex operation and collision-free environment
  - 9.8.3. IEEE 802.3x flow control
  - 9.8.4. Priority queuing and virtual LAN support
  - 9.8.5. Loss-of-link management
  - 9.8.6. Remote monitoring, port mirroring, and diagnostics
  - 9.8.7. LAN-based network protocols
  - 9.8.8. Ethernet-based protection message standards
  - 9.8.9. Ethernet-based SEL product portfolio
  - 9.8.10. Ethernet radio
- 9.9. Future trends
- 9.10. References

## **10. Information processing**

- 10.1. Introduction
- 10.2. Operations technology and information technology
- 10.3. Integrated IEDs networks
  - 10.3.1. Communication makes IEDs informed and organized
  - 10.3.2. Hierarchical levels of integrated IED networks
  - 10.3.3. Serial networks and Ethernet local-area networks
  - 10.3.4. Star, multidrop, and ring LAN configurations
  - 10.3.5. SEL Best Practice Methods support serial and Ethernet LANs
- 10.4. SEL specialized IEDs improve data processing
  - 10.4.1. Categories of power system data
  - 10.4.2. SEL IEDs provide superior performance

- 10.4.3. SEL IED communication surpasses that focused only on SCADA
- 10.4.4. SEL IEDs create situational awareness
- 10.4.5. SEL IEDs create apparatus data models
- 10.4.6. Migration to routable protocols reduces security and increases complexity
- 10.5. SEL increases LAN functionality
  - 10.5.1. SEL Best Practices based on scientific measures
  - 10.5.2. Different networks require different information processors
  - 10.5.3. Data processing
  - 10.5.4. Automation
  - 10.5.5. Network functions
  - 10.5.6. Information notification and visualization
  - 10.5.7. Other SEL advantages
- 10.6. Create best-in-class networks
  - 10.6.1. Modern communications methods satisfy IED network tasks
  - 10.6.2. SEL-8000 provides for new generation networks
- 10.7. Use IEC 61850 network evaluation methods
  - 10.7.1. SEL designs for availability
  - 10.7.2. SEL designs for performance
- 10.8. SEL IEDs monitor, decide, and act
  - 10.8.1. Separate protection and automation
  - 10.8.2. Automate with networked SEL IEDs
  - 10.8.3. SEL versatility
- 10.9. References

## **11. Information security**

- 11.1. Introduction
- 11.2. Important security tips
- 11.3. Attacker profile and motivation
  - 11.3.1. Advantages of electronic attack methods
  - 11.3.2. Groups that threaten the electric power infrastructure
- 11.4. Attack techniques and tools
  - 11.4.1. Network reconnaissance
  - 11.4.2. Active scanning
  - 11.4.3. Exploiting vulnerabilities
  - 11.4.4. Attack propagation
- 11.5. Prioritizing electronic security risks in the electric power industry
- 11.6. Defensive technologies and strategies
  - 11.6.1. Electronic attack barriers
  - 11.6.2. Defining the electronic security perimeter
  - 11.6.3. Limiting access to protected networks
  - 11.6.4. Implementing strong cryptographic link security
  - 11.6.5. Implementing strong, local electronic access controls in critical devices
  - 11.6.6. Securing personal computers
- 11.7. Detecting and responding to electronic attacks
- 11.8. References

## **12. Protection system reliability and testing**

- 12.1. Introduction

- 12.2. Reliability concepts
  - 12.2.1. Definitions and measures
  - 12.2.2. Failure rates and patterns of failure
- 12.3. System reliability analysis methods
  - 12.3.1. Block diagram method
  - 12.3.2. Fault-tree analysis method
- 12.4. Improving availability
  - 12.4.1. Redundant protection systems
  - 12.4.2. Design considerations for redundant protection systems
  - 12.4.3. Aviation industry comparison
  - 12.4.4. Advantages of redundant protection configurations
  - 12.4.5. Effect of common-mode failures
- 12.5. Selecting reliable protective relays
  - 12.5.1. Designing products for quality and reliability
  - 12.5.2. Thoroughly testing products before release
  - 12.5.3. Manufacturing for reliability
  - 12.5.4. Using field data to improve product reliability
- 12.6. Relay testing and commissioning
  - 12.6.1. Microprocessor-based relay self-tests
  - 12.6.2. Additional microprocessor-based relay monitoring features
  - 12.6.3. Testing microprocessor-based relays
- 12.7. References

## **13. Substation protection, control, and monitoring system design**

- 13.1. Introduction
- 13.2. Design objectives of substation protection, control, and monitoring systems
  - 13.2.1. Functional requirements
  - 13.2.2. Design objectives
  - 13.2.3. Benefits of system integration and automation
- 13.3. DC control power system requirements for substations
  - 13.3.1. Battery monitoring features built into SEL relays
  - 13.3.2. External battery monitoring systems
- 13.4. Protection system redundancy
- 13.5. DC logic circuit design
  - 13.5.1. Circuit layout
  - 13.5.2. DC system fault protection
  - 13.5.3. Tripping/closing circuit design
  - 13.5.4. Auxiliary relays
  - 13.5.5. Remote I/O modules
  - 13.5.6. Targeting considerations
  - 13.5.7. Manual control system design
  - 13.5.8. Using communications links for critical protection and control functions
- 13.6. AC sensing circuit design
  - 13.6.1. Circuit design
  - 13.6.2. Power system protection circuits
  - 13.6.3. Metering circuits
  - 13.6.4. Transient recording
  - 13.6.5. Continuous monitoring of device measurements
- 13.7. Application of test switches

- 13.8. Design documentation
  - 13.8.1. Complete design documentation package
  - 13.8.2. DC elementary (schematic) diagrams
  - 13.8.3. Logic diagrams
  - 13.8.4. Standards
- 13.9. Panel and substation control enclosure design
  - 13.9.1. Purpose of a substation control enclosure
  - 13.9.2. Protection, control, and monitoring panel design
  - 13.9.3. Effects of integrated protection, control, and monitoring systems on enclosure design
  - 13.9.4. Substation control enclosure environmental system
  - 13.9.5. Eliminating the centralized control enclosure
- 13.10. References

## **14. Using power system information**

- 14.1. Introduction
- 14.2. Asset management
- 14.3. SEL multifunction relays: a wealth of information
- 14.4. Upgrading protection, control, and monitoring equipment
- 14.5. Upgrading a substation using SEL multifunction relays
  - 14.5.1. Integrated system architecture
  - 14.5.2. System functionality
  - 14.5.3. Substation control enclosure
  - 14.5.4. Additional cost considerations
- 14.6. Data monitoring and analysis improve asset management
  - 14.6.1. Data flow
  - 14.6.2. Transformer monitoring
  - 14.6.3. Breaker monitoring
  - 14.6.4. Capacitor bank monitoring
  - 14.6.5. Battery monitoring
  - 14.6.6. Synchroscope for autosynchronizer
  - 14.6.7. Substation control enclosure and weather monitoring
  - 14.6.8. Applications
- 14.7. References

## **Index**