



CONTROLLER SIMULATED SURGE ARRESTER OPERATION TEST REPORT

Client: Schweitzer Engineering Laboratories, 2350 NE Hopkins Court, Pullman, WA 99163-5603, USA	
Test Date: 7 & 8 November 2005	Project: 16063-27
Nameplate Data:	
Controller:	
Manufacturer:	Schweitzer Engineering Laboratories, Pullman, Washington, USA
Model No.:	0351R2128Q11HXCXX
Serial No.:	2005122186
Recloser:	
Manufacturer:	Cooper Power Systems
Type:	Nova 27
Impulse level (BIL):	125 kV _{peak}
Rated voltage:	27 kV _{rms}
Rated current:	630 A _{rms} continuous; 12.5 kA interrupting
Serial No.:	4925-BH
Test Witness: Kenneth G. Workman, Schweitzer Engineering Laboratories Francois Soulard, Hydro Québec Jacques Côté and Jean-Francois Briand, Grimard	
Test Standard: IEEE Std C37.60-2003, Clause 6.13.2: "Simulated Surge Arrester Operation Test"	
Atmospheric Conditions:	
Temperature	19.7 °C
Relative humidity	36%
Barometric pressure	755.8 mmHg
Test Current: 7 kA _{peak}	
Test Configurations (in accordance with the above standard):	
A – surges applied to the source bushing with the recloser open B – surges applied to the source bushing with the recloser closed C – surges applied to the load bushing with the recloser closed D – surges applied to a properly rated transformer with the recloser open E – surges applied to a properly rated transformer with the recloser closed	
Test Results: The controller and recloser operated normally following the Simulated Surge Arrester Operation Test performed in accordance with the test procedures as per the above standard. The controller complied with the requirements of IEEE Std C37.60-2003, Clause 6.13.2.	
Remarks: None	

Prepared by:


 Milan Vasko, P.Eng. 22 Feb 2006
 Senior Electrical Engineer

Approved by:


 A.J. Vandermaar, P.Eng. 06/02/22
 Manager, High Voltage Laboratory


This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.

CONTROLLER OSCILLATORY SWC TEST REPORT


Client:	Schweitzer Engineering Laboratories, 2350 NE Hopkins Court, Pullman, WA 99163-5603, USA	
Test Date:	9 November 2005	Project: 16063-27
Nameplate Data:		
Controller:		
Manufacturer:	Schweitzer Engineering Laboratories, Pullman, Washington, USA	
Model No.:	0351R2128Q11HXCXX	
Serial No.:	2005122186	
Recloser:		
Manufacturer:	Cooper Power Systems	
Type:	Nova 27	
Impulse level (BIL):	125 kV _{peak}	
Rated voltage:	27 kV _{rms}	
Rated current:	630 A _{rms} continuous; 12.5 kA interrupting	
Serial No.:	4925-BH	
Test Witness:	Kenneth G. Workman, Schweitzer Engineering Laboratories Francois Soulard, Hydro Québec Jacques Côté and Jean-Francois Briand, Grimard	
Test Standard:	IEEE Std C37.60-2003, Clause 6.13.1: "Oscillatory and Fast Transients Surge Tests"	
Test Voltage:	2.5 kV _{peak}	
Test Procedure:	Test surge applied in common mode and transverse mode to wire pairs.	
Test Results:	The controller and recloser operated normally following the Oscillatory SWC Test performed in accordance with the test procedures. The controller complied with requirements of IEEE C37.60-2003, Clause 6.13.1.	
Remarks:	The controller passed the test.	

Tested by:

Approved by:



Robert G. Pollock
 Senior Project Specialist



A.J. Vandermaar, P.Eng. 06/02/2006
 Manager, High Voltage Laboratory

This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.

APPENDIX 1

Oscillatory SWC Waveform Validity Tests
 (in accordance with IEEE Std C37.90.1-2002, Clause A.2)

Performed before the Oscillatory SWC Test

1. Measuring system feedthrough test

Generator Output voltage 2.5 kV
 Feedthrough voltage 2.1 V (pass $\leq 1\%$)

2. Open circuit voltage waveform test

Recorded waveforms – Figures 1 and 2.

3. Test Generator performance verification

Rise time of the first peak	<u>84</u> ns	(60 to 90 ns – 10% to 90%)
Peak voltage level (no load)	<u>2.5</u> kV	(2.25 to 2.5 kV when set to 2.5 kV)
Output impedance	<u>199</u> Ω	(160 to 240 Ω)
Waveform envelope decay	<u>4.94</u> μ s	(4 to 6 μ s to 50%)
Oscillation frequency	<u>0.917</u> MHz	(0.9 to 1.1 MHz)
Repetition rate	<u>8</u> bursts per period	(6-10 bursts per 16.7 mS)
Test duration	<u>2.2</u> s	(2 to 2.2 s)

4. Test Pass X Test Fail _____




Figure 1




Figure 2

This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.

APPENDIX 2

Oscillatory SWC Waveform Validity Tests
(in accordance with IEEE Std C37.90.1-2002, Clause A.2)

Performed after the Oscillatory SWC Test

4. Measuring system feedthrough test

Generator Output voltage 2.5 kV
 Feedthrough voltage 0 V (pass $\leq 1\%$)

5. Open circuit voltage waveform test

Recorded waveforms – Figures 1 and 2.

6. Test Generator performance verification

Rise time of the first peak	<u>68</u> ns	(60 to 90 ns – 10% to 90%)
Peak voltage level (no load)	<u>2.5</u> kV	(2.25 to 2.5 kV when set to 2.5 kV)
Output impedance	<u>194.7</u> Ω	(160 to 240 Ω)
Waveform envelope decay	<u>6.0</u> μ s	(4 to 6 μ s to 50%)
Oscillation frequency	<u>0.91</u> MHz	(0.9 to 1.1 MHz)
Repetition rate	<u>8</u> bursts per period	(6-10 bursts per 16.7 ms)
Test duration	<u>2.2</u> s	(2 to 2.2 s)

5. Test Pass X Test Fail _____




Figure 1




Figure 2


This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.

CONTROLLER FAST TRANSIENT SWC TEST REPORT

Client:	Schweitzer Engineering Laboratories, 2350 NE Hopkins Court, Pullman, WA 99163-5603, USA	
Test Date:	9 November 2005	Project: 16063-27
Nameplate Data:		
Controller:		
Manufacturer:	Schweitzer Engineering Laboratories, Pullman, Washington, USA	
Model No.:	0351R2128Q11HXCXX	
Serial No.:	2005122186	
Recloser:		
Manufacturer:	Cooper Power Systems	
Type:	Nova 27	
Impulse level (BIL):	125 kV _{peak}	
Rated voltage:	27 kV _{rms}	
Rated current:	630 A _{rms} continuous; 12.5 kA interrupting	
Serial No.:	4925-BH	
Test Witness:	Kenneth G. Workman, Schweitzer Engineering Laboratories Francois Soulard, Hydro Québec Jacques Côté and Jean-Francois Briand, Grimard	
Test Standard:	IEEE Std C37.60-2003, Clause 6.13.1: "Oscillatory and Fast Transients Surge Tests"	
Test Voltage:	4.0 kV _{peak}	
Test Procedure:	Test surge applied in common mode and transverse mode to wire pairs.	
Test Results:	The controller and recloser operated normally following the Fast Transient SWC Test performed in accordance with the test procedures. The controller complied with the requirements of IEEE C37.60-2003, Clause 6.13.1.	
Remarks:	The controller passed the test.	

Tested by:

Approved by:



Robert G. Pollock
 Senior Project Specialist



A.J. Vandermaar, P.Eng. 06/02/22
 Manager, High Voltage Laboratory

This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.

APPENDIX 1

Fast Transient SWC Waveform Validity Tests
(in accordance with IEEE Std C37.90.1-2002, Clause A.2)

Performed before the Fast Transient SWC Test

1. Measuring system feedthrough test

Generator Output voltage 4 kVFeedthrough voltage 0.22 V (pass if $\leq 1\%$)

2. Open circuit voltage waveform test

Recorded waveforms – Figures 1 and 2.

3. Test Generator performance verification


Rise time 3.6 ns (3.5 to 6.5 ns – 10% to 90%)Peak voltage level (no load) 4.3 kV (3.6 to 4.4 kV when set to 4 kV)Output impedance 44.3 Ω (40 to 60 Ω)Impulse duration 65 ns (35 to 65 ns to 50% value)Repetition rate 2.5 kHz (2 to 3 kHz)Burst duration 14.9 ms (12 to 18 ms)Burst period 300 ms (240 to 360 ms)Test duration 60.0 s (≥ 60 s)4. Test Pass X Test Fail _____

Figure 1




Figure 2

This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.

APPENDIX 2

Fast Transient SWC Waveform Validity Tests
(in accordance with IEEE Std C37.90.1-2002, Clause A.2)

Performed after the Fast Transient SWC Test

5. Measuring system feedthrough test

Generator Output voltage 4 kV
 Feedthrough voltage 0.1 V (pass if $\leq 1\%$)

6. Open circuit voltage waveform test

Recorded waveforms – Figures 1 and 2.

7. Test Generator performance verification

Rise time	<u>4</u> ns	(3.5 to 6.5 ns – 10% to 90%)
Peak voltage level (no load)	<u>4.4</u> kV	(3.6 to 4.4 kV when set to 4 kV)
Output impedance	<u>45.5</u> Ω	(40 to 60 Ω)
Impulse duration	<u>52</u> ns	(35 to 65 ns to 50% value)
Repetition rate	<u>2.5</u> kHz	(2 to 3 kHz)
Burst duration	<u>15.0</u> ms	(12 to 18 ms)
Burst period	<u>301</u> ms	(240 to 360 ms)
Test duration	<u>60.0</u> s	(≥ 60 s)

8. Test Pass X Test Fail _____




Figure 1




Figure 2

This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.