

**RECLOSER CONTROLLER SIMULATED SURGE ARRESTER OPERATION TEST REPORT**

<b>Client:</b>	Schweitzer Engineering Laboratories, Inc., 2350 NE Hopkins Court, Pullman, WA – 99163, USA		
<b>Test Date:</b>	16 November and 17 November, 2010	<b>Project:</b>	20380-27
<b>Nameplate Data:</b>			
<b>Three-Phase Recloser Controller:</b>			
Manufacturer:	Schweitzer Engineering Laboratories, Inc., Pullman, WA, USA		
Model:	SEL-651R		
Part No.:	0651R11VAA8211X3XX		
Serial No.:	2010286530		
<b>Three-Pole Recloser:</b>			
Manufacturer:	Cooper Power Systems, South Milwaukee, WI, USA		
Model:	Kyle Recloser Type "Nova27"		
Impulse Level (BIL):	150 kV <sub>peak</sub>		
Rated Voltage:	27 kV <sub>rms</sub>		
Rated Current:	630 A <sub>rms</sub> / 12.5 kA <sub>rms</sub> interrupting		
Serial No.:	CP571178011-DH		
<b>Test Witnesses:</b>	Mark Feltis, Schweitzer Engineering Laboratories, Inc., Pullman, WA, USA		
<b>Test Standard:</b>	IEEE Std C37.60-2003, Clause 6.13.2: "Simulated Surge Arrester Operation Test"		
<b>Atmospheric Conditions:</b>		<u>16 November 2010</u>	<u>17 November 2010</u>
	Temperature	16.4 °C	16.5 °C
	Relative humidity	47.3 %	38 %
	Barometric pressure	751.5 mmHg	745.3 mmHg
<b>Nominal Test Voltage and Current:</b>	120 kV (150 kV * 0.8), 7 kA <sub>peak</sub>		
<b>Test Configurations Tested</b> (in accordance with the above standard):			
<p>A – Five surges of positive polarity and five surges of negative polarity were applied to each of the three source bushing with the recloser open (total ten surges per bushing).          B – Five surges of positive polarity and five surges of negative polarity were applied to each of the three source bushing with the recloser closed (total ten surges per bushing).          C – Five surges of positive polarity and five surges of negative polarity were applied to each of the three load bushing with the recloser closed (total ten surges per bushing).          D – 15 surges of positive polarity and 15 surges of negative polarity were applied to a properly rated transformer with the recloser closed.          E – 15 surges of positive polarity and 15 surges of negative polarity were applied to a properly rated transformer with the recloser open.</p>			
<b>Test Results:</b>	The controller and switch complied with the requirements of IEEE Std C37.60-2003, Clause 6.13.2, configurations A to E.		
<b>Remarks:</b>	None		

Tested by:

Reviewed by:



R.G. Pollock,  
 Senior Projects Specialist



A.J. Vandermaar, P.Eng.  
 Manager, High Voltage Laboratory

*This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.*