


**CONTROLLER OSCILLATORY SWC TEST REPORT**

<b>Client:</b>	Schweitzer Engineering Laboratories, 2350 NE Hopkins Court, Pullman, WA 99163-5603, USA	
<b>Test Date:</b>	October 26, 2004	<b>Project:</b> 15341-27
<b>Nameplate Data:</b>		
<b>Controller:</b>		
Manufacturer:	Schweitzer Engineering Laboratories, Pullman, Washington, USA	
Model No.:	0651R011AA820113XX	
Serial No.:	2004236259	
<b>Recloser:</b>		
Manufacturer:	Cooper	
Type:	Nova 27	
Impulse level (BIL):	125 kV <sub>peak</sub>	
Rated voltage:	27 kV <sub>rms</sub>	
Rated current:	630 A <sub>rms</sub> continuous; 12.5 kA interrupting	
Serial No.:	A-002075	
<b>Test Witness:</b>	Darin McKee & Kenneth G. Workman, Schweitzer Engineering Laboratories	
<b>Test Standard:</b>	IEEE Std C37.60-2003, Clause 6.13.1: "Oscillatory and fast transients surge tests"	
<b>Test Voltage:</b>	2.5 kV <sub>peak</sub>	
<b>Test Procedure:</b>	Test surge applied in common mode and transverse mode to wire pairs.	
<b>Test Results:</b>	The controller and recloser operated normally following the Oscillatory SWC Test performed in accordance with the test procedures. The controller complied with requirements of IEEE C37.60-2003, Clause 6.13.1.	
<b>Remarks:</b>	The controller passed the test.	

Tested by:

Approved by:

  
Robert G. Pollock  
Senior Project Specialist

  
A.J. Vandermaar, P.Eng.  
Manager, High Voltage Laboratory

*This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.*


**CONTROLLER FAST TRANSIENT SWC TEST REPORT**

<b>Client:</b>	Schweitzer Engineering Laboratories, 2350 NE Hopkins Court, Pullman, WA 99163-5603, USA	
<b>Test Date:</b>	October 25, 2004	<b>Project:</b> 15341-27
<b>Nameplate Data:</b>		
<b>Controller:</b>		
Manufacturer:	Schweitzer Engineering Laboratories, Pullman, Washington, USA	
Model No.:	0651R011AA820133XX	
Serial No.:	2004236259	
<b>Recloser:</b>		
Manufacturer:	Cooper	
Type:	Nova 27	
Impulse level (BIL):	125 kV <sub>peak</sub>	
Rated voltage:	27 kV <sub>rms</sub>	
Rated current:	630 A <sub>rms</sub> continuous; 12.5 kA interrupting	
Serial No.:	A-002075	
<b>Test Witness:</b>	Darin McKee & Kenneth G. Workman, Schweitzer Engineering Laboratories	
<b>Test Standard:</b>	IEEE Std C37.60-2003, Clause 6.13.1: "Oscillatory and fast transients surge tests"	
<b>Test Voltage:</b>	4.0 kV <sub>peak</sub>	
<b>Test Procedure:</b>	Test surge applied in common mode and transverse mode to wire pairs.	
<b>Test Results:</b>	The controller and recloser operated normally following the Fast Transient SWC Test performed in accordance with the test procedures. The controller complied with the requirements of IEEE C37.60-2003, Clause 6.13.1.	
<b>Remarks:</b>	The controller passed the test.	

Tested by:

Approved by:

  
 for Robert G. Pollock 18 Nov 2004  
 Senior Project Specialist


  
 A.J. Vandermaar, P.Eng. 18 Nov 04  
 Manager, High Voltage Laboratory

*This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.*


## CONTROLLER SIMULATED SURGE ARRESTER OPERATION TEST REPORT

<b>Client:</b>	Schweitzer Engineering Laboratories, 2350 NE Hopkins Court, Pullman, WA 99163-5603, USA		
<b>Test Date:</b>	26 October 2004	<b>Project:</b>	15324-27
<b>Nameplate Data:</b>			
<b>Controller:</b>			
Manufacturer:	Schweitzer Engineering Laboratories, Pullman, Washington, USA		
Model No.:	0651R011AA820113XX		
Serial No.:	2004236259		
<b>Recloser:</b>			
Manufacturer:	Cooper Power Systems		
Type:	Nova 27		
Impulse level (BIL):	125 kV <sub>peak</sub>		
Rated voltage:	27 kV <sub>rms</sub>		
Rated current:	630 A <sub>rms</sub> continuous; 12 kA interrupting		
Serial No.:	A-0002075		
<b>Test Witness:</b>	Darin McKee & Kenneth G. Workman, Schweitzer Engineering Laboratories		
<b>Test Standard:</b>	IEEE Std C37.60-2003, Clause 6.13.2: "Simulated Surge Arrester Operation Test"		
<b>Atmospheric Conditions:</b>	Temperature	25.9 °C	
	Relative humidity	48 %	
	Barometric pressure	758.6 mmHg	
<b>Test Current:</b>	7 kA <sub>peak</sub>		
<b>Test Configurations</b> (in accordance with the above standard):			
A – surges applied to the source bushing with the recloser open B – surges applied to the source bushing with the recloser closed C – surges applied to the load bushing with the recloser closed D – surges applied to a properly rated transformer with the recloser open E – surges applied to a properly rated transformer with the recloser closed			
<b>Test Results:</b>	The controller and recloser operated normally following the Simulated Surge Arrester Operation Test performed in accordance with the test procedures as per the above standard. The controller complied with requirements of IEEE Std C37.60-2003, Clause 6.13.2.		
<b>Remarks:</b>	None		

Prepared by:

  
 Milan Vasko, P.Eng. 18 Nov 2004  
 Senior Electrical Engineer

Approved by:

  
 A.J. Vandermaar, P.Eng. 18 Nov. 04  
 Manager, High Voltage Laboratory

*This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.*