



CONTROLLER SIMULATED SURGE ARRESTER OPERATION TEST REPORT

Client:	Schweitzer Engineering Laboratories, 2350 NE Hopkins Court, Pullman, WA 99163-5603, USA	
Test Date:	4 & 5 July 2003	Project: 14457-27(C)
Nameplate Data:		
Controller:		
Manufacturer:	Schweitzer Engineering Laboratories	
Model:	SEL-651R	
Part No.:	0651R01AAA821123A0+17	
Serial No.:	Cooper-7	
Recloser:		
Manufacturer:	Cooper Power Systems	
Model:	Kyle Recloser Type WVE-27	
Impulse level (BIL):	150 kV _{peak}	
Rated voltage:	38 kV _{rms}	
Rated current:	560 A _{rms} continuous, 8 kA _{rms} interrupting	
Dielectric:	Non-PCB fluid	
Serial No.:	009750	
Test Witness:	Greg Bow and Kenneth G. Workman, Schweitzer Engineering Laboratories	
Test Standard:	IEEE Std C37.60-2003, Clause 6.13.2: "Simulated Surge Arrester Operation Test"	
Atmospheric Conditions:	Temperature	20.7 °C
	Relative humidity	41 %
	Barometric pressure	756.5 mmHg
Test Current:	7 kA _{peak}	
Test Configurations (in accordance with the above standard):		
	A – surges applied to the source bushing with the recloser open	
	B – surges applied to the source bushing with the recloser closed	
	C – surges applied to the load bushing with the recloser closed	
	D – surges applied to a properly rated transformer with the recloser open	
	E – surges applied to a properly rated transformer with the recloser closed	
Test Results:	The controller and recloser operated normally following the Simulated Surge Arrester Operation Test performed in accordance with the test procedures as per the above standard. The controller complied with requirements of IEEE Std C37.60-2003, Clause 6.13.2.	
Remarks:	The controller passed the test.	

Prepared by:


 Milan Vasko
 Senior Electrical Engineer
 22 Aug 2003

Approved by:


 A.J. Vandermaar, P.Eng.
 Manager, High Voltage Laboratory
 03/08/22


This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.

Test Report № 14460-26


Manufacturer:	Schweitzer Engineering Labs Pullman, WA 99163-5603, USA	
Project №:	#14460-26	Test Dates: 3 July 2003
Tested Device:	Recloser Control Unit	
Type:	SEL-651R	
Product №:	0651RO1AAA821123AO+17	
Serial №:	Cooper - 7	
Tested Recloser:	Kyle Recloser Type "WVE-27", 27 kV, 8 kA, 630 A, Serial № 009750	
Tests performed:	<ul style="list-style-type: none"> • Transformer Magnetizing Current tests at 22.0 kV, 23.0 A_{RMS}, 20 x CO operations • Line Charging Current tests at 22 kV, 5.63 A_{RMS}, 20 x CO operations 	
Witnesses:	Mr. Gregory A. Bow Mr. Ken Workman	Schweitzer Engineering Labs Co. Schweitzer Engineering Labs Co.
Remarks:	Identification of the Tested Recloser and Recloser Control Unit was based on the nameplate information. The tests were performed under conditions similar to those specified in ANSI/IEEE Standard C37.60-1981, Section 6.13 and ANSI/IEEE C37.60, Draft 15a (Unapproved), published in November 2002, Section 6.3.2.2.2.	

Tested by:

Reviewed by:


15 August 2003

T. Stefanski M.Sc., P. Eng.
Head of High Power Lab



J.A. Zawadzki M.Sc., P. Eng.
Director, Power Engineering Labs

This report shall not be reproduced except in full, without the written approval of Powertech Labs Inc.